


Project Information:



DG Engineering LLC
 6019 Cerritos Houston, TX 77035
 Ph) 713-729-6125 F) 713-729-6135
 TPEE FIRM # 7669

SHOPS ON GOSLING
 RETAIL CENTER
 SHELL BUILDING DEVELOPMENT
 24309 GOSLING ROAD
 SPRING, TEXAS 77389

Sheet Title:

**ELECTRICAL
 Plans**

Issue:

CD/PERMIT

Issue Date:

10 DECEMBER 2018 - SD
 12 MARCH 2019 - CD/PERMIT

Revision Date:

Sheet:

E1.01



- ELECTRICAL SITE PLAN KEYED NOTES:**
- ① PROPOSED PAD MOUNTED TRANSFORMERS FOR SERVICE TO THIS PROPERTY. CONTRACTOR TO BUILD CONCRETE PAD WITH LEAVE-OUTS FOR PRIMARY AND SECONDARY IN COORDINATION WITH CENTERPOINT ENERGY STANDARDS. COORDINATE WITH SERVICE REPRESENTATIVE AND SERVICE TERMS AND CONDITIONS AGREEMENT.
 - ② UNDERGROUND PRIMARY SERVICE TO TRANSFORMER. CONTRACTOR TO INSTALL 2-6" EMPTY CONDUIT ENCASED IN CONCRETE FROM TERMINAL POLE TO PRIMARY SECTION OF PAD. INSTALL PER CENTERPOINT STANDARDS.
 - ③ CENTERPOINT ENERGY SERVICE TERMINAL POLE.
 - ④ UNDERGROUND SERVICE TO BUILDING SERVICE WIREWAY. SEE ONE LINE DIAGRAM.
 - ⑤ SERVICE WIREWAY FOR DISTRIBUTION TO TENANT SERVICES.
 - ⑥ PROVIDE POWER TO MONUMENT SIGN. COORDINATE INSTALLATION AND ELECTRICAL REQUIREMENTS WITH OWNER'S SIGN MANUFACTURER.
 - ⑦ SITE LIGHTING. SEE POLE BASE DETAIL.
 - ⑧ CENTERPOINT ENERGY EASEMENT FOR OVERHEAD POWER AND GUY WIRE. COORDINATE WITH CENTERPOINT, REPRESENTATIVE, SITE LIGHTING AND ASSOCIATED WIRING SHALL BE INSTALLED TO AVOID VIOLATION OF THIS EASEMENT.
 - ⑨ POWER TO MONUMENT SIGN. PROVIDE 30/2/NF/NEAR DISC SWITCH AT SIGN. COORDINATE WITH SIGN CONTRACTOR PRIOR TO FINAL CONNECTIONS TO VERIFY SIGN REQUIREMENTS.

1 ELECTRICAL SITE PLAN
 1" = 30'

COPYRIGHT © GOULAS + ASSOCIATES, INC. ALL DRAWINGS, SPECIFICATIONS AND DESIGNS APPEARING HEREIN CONSTITUTE THE ORIGINAL AND UNPUBLISHED WORK OF THE ARCHITECT. DESIGNER AND HIS/HER ASSOCIATES, AND THE SAME MAY NOT BE DUPLICATED, USED OR DISCLOSED WITHOUT THE EXPRESS WRITTEN CONSENT OF THE ARCHITECT/DESIGNER.